



Republic of the Philippines
Department of Agriculture
Fertilizer and Pesticide Authority
FPA Bldg. BAI Compound, Visayas Ave. Diliman, Quezon City P.O. Box 2582, Q.C.
Tel. Nos. 8920-8573, 8441-1601, 8922-3368
E-mail add: fpacentral77@gmail.com | Website: <http://fpa.da.gov.ph>

Procurement of Heavy Duty UPS Supplement No. 1

The herein Supplement No. 1 is issued to inform all prospective suppliers for the **Procurement of Heavy Duty UPS** of the following changes in the Technical Specifications, to wit:

Output power capacity	10 KWatts / 10 kVA
Max Configurable Power (Watts)	10 KWatts / 10 kVA
Output Voltage	220/230/240V
Output Frequency Range (Battery Mode)	50/60 \pm 0.05 Hz
Parallel Operation	Up to 3 units
Transfer Time	
Battery Mode \leftrightarrow Inverter Mode	0ms
Inverter Mode \leftrightarrow Bypass Mode	0ms
ECO Mode \leftrightarrow Battery Mode	10ms
Nominal Input Voltage	110~276VAC
Input frequency	40-70Hz
Input Wiring	Single phase with ground
Typical recharge time	3 hour(s) to 90%

Supplement No. 1 is issued and adopted as amendment and made an integral part of the Request for Quotation pursuant to Solicitation No. **RFQ-2020-12-03**.

Issued this 4th day of December 2020 at the Quezon City, Philippines.


DIGNA M. DE LEON
Chairperson, Bids and Awards Committee

A food-secure Philippines
with prosperous farmers and fisherfolk

